## Embodied Carbon Calculator: Mid-level Report



## (CIBSE TM65 Digital Tool)

If Section A of the 'Input' tab is correctly completed, the results will be shown here. Please complete all purple and yellow cells.

If you would like to assist CIBSE in building knowledge on the embodied carbon of products used in building services, please complete as directed above, name this file as instructed in the 'Introduction and Instructions' tab, and email this file to embodiedcarbon@cibse.org.

If you are a manufacturer and would like to share the results of your calculations with clients, please create PDFs of the relevant tabs ONLY (instructions are available in the 'Introduction and Instructions' tab). You may not share any CIBSE tool with clients. Instead, please refer any interested party to www.cibse.org/TM65, where they will be able to download the most up-to-date version of the relevant CIBSE tool.

## Mid-level report for LBX66WHS40-03 as manufacturerd by Luceco PLC

'Mid-level' calculation		Notes/source
Date of assessment	14/08/24	Form "dd/mm/yy"
Name of assessor and assessor organisation	Self Assessment	
Contact email address of assessor	kira.chen@luceco.com	

Product information			
Type of product	Luminaires		
Capacity of equipment/size (kW; m <sup>3</sup> ; litres; etc.)	0.03 kW		
Product weight (kg)	1.96 kg		
Material % breakdown for at least 95% of the product weight? $(Y/N)$	Y		
Product service life (years)	10 Years		
If refrigerant based, type of refrigerant used and GWP	No refrigerant, 0 kgCO2e		
Refrigerant charge (kg)	0.00 kg		
Energy consumption of the factory* per unit of product	0.34 kWh	Electricity - Asia,Gas - Global	
Location of manufacture*	Jiaxing, Zhejiang, China		
Product complexity category	Category 2	See CIBSE TM65 Table 4.3	

Embodied carbon results (kg CO2e) — breakdown			
A1: Material extraction	11 kgCO2e	TM65 assumption	
A2: Transport	1 kgCO2e	TM65 assumption	
A3: Manufacturing	1 kgCO2e		
A4: Transport to site	0 kgCO2e	TM65 assumption	
A5: Construction	n/a		
B1: Refrigerant leakage during use	0 kgCO2e	TM65 leakage Type 0	
B2: Maintenance (if information given by manufacturer)	n/a		
B3: Repair	0 kgCO2e	TM65 assumption	
B4: Replacement	n/a		
B5: Refurbishment	n/a		
B6: Operational energy	n/a		
B7: Operational water	n/a		
C1: Refrigerant leakage when decommissioning	0 kgCO2e	TM65 leakage Type 0	
C2: Transport	0 kgCO2e		
C3: Waste processing	0 kgCO2e		
C4: Disposal	0 kgCO2e	TM65 assumption	

Embodied carbon results (kg CO2e) — without refrigerant leakage				
A1-C4 without buffer factor (excluding B1, C1)	13 kgCO2e			
A1-C4 with buffer factor (excluding B1, C1)	16 kgCO2e			
Embodied carbon result (kg $CO_2e$ ) — refrigerant leakage only				
Embodied carbon	result (kg CO2e) - refrigerant leakag	e only		

## Embodied carbon result with 'mid-level' calculation method (kg CO2e) - total Result of 'mid-level' calculation method

16 kgCO2e

Assumptions			
A1: Material carbon coefficient source	Source = CIBSE TM65, Table 2.1	E.g.: Source = CIBSE TM65, Table 2.1	
B1: Refrigerant annual leakage rate (%)	0%	E.g.: Source = CIBSE TM65, Table 4.13 type 2	
C1: Refrigerant end of life recovery rate (%)	100%	E.g.: Source = CIBSE TM65, Table 4.13 type 2	
B3: Materials replaced as part of repair (%)	2%	E.g.: Source = CIBSE TM65	
C4: Percentage of product going to landfill (%)	55%	E.g.: Source = CIBSE TM65	

Details

Please provide any relevant details
\* Please provide information on the final assembly factory. If you have more information on energy consumption of factories in the supply chain, email embodiedcarbon@cibse.org.